

Number	19-005118-PR06 (NW-K23-09-en-01)
Owner	Münchinger Holz GmbH Gewerbepark Wiedersbach 91578 Leutershausen Germany
Product	Symmetrically laminated and finger-jointed timber profile of quality sorted and dried timber
Designation	System: Block profile 3-fold glued
Details	Material Spruce; Configuration laminated cross section and longitudinally finger-jointed lamella in the core layers; Type of adhesive 2K-Weißleim D4; Adhesive Technobond 4201/D4; Hardener Aluminium-Chlorid-Härter; Cross section (W x T) 87 mm x 72 mm
Special features	-/-

## Result

Classification of laminated profiles according to CEN/TS 13307-2 / DIN SPEC 1140:2009-12



**The requirements for the service class 3 according to CEN/TS 13307-2 regarding the separation of layers are fulfilled.**

## Basis \*)

EN 13307-1:2006-11

CEN/TS 13307-2:2009-12  
\*) and corresponding national versions  
(e.g. DIN EN)

Test report: 19-005118-PR06 PB-K23-09-de-01

## Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

## Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim  
27.10.2020



Dr. Ing. Odette Moarcas  
Head of Testing Department  
Fire Safety



Stefan Hehn, Dipl.-Ing. (FH)  
Operating Testing Officer  
Material Testing

## Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: FEF-7F206