

Number	19-005118-PR05 (NW-K23-09-en-01)
Owner	Münchinger Holz GmbH Gewerbepark Wiedersbach 91578 Leutershausen Germany
Product	Symmetrically laminated and finger-jointed timber profile of quality sorted and dried timber
Designation	System: Block profile 3-fold glued
Details	Material Pine; Configuration laminated cross section and longitudinally finger-jointed lamella in the core layers; Type of adhesive 2K-Weißleim D4; Adhesive Technobond 4201/D4; Hardener Aluminium-Chlorid-Härter; Cross section (W x T) 88 mm x 72 mm
Special features	-/-

Result

Classification of laminated profiles according to CEN/TS 13307-2 / DIN SPEC 1140:2009-12



The requirements for the service class 3 according to CEN/TS 13307-2 regarding the separation of layers are fulfilled.

Basis *)

EN 13307-1:2006-11

CEN/TS 13307-2:2009-12

*) and corresponding national versions (e.g. DIN EN)

Test report: 19-005118-PR05 PB-K23-09-de-01

Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

26.10.2020



Dr. Ing. Odette Moarcas
Head of Testing Department
Fire Safety



Stefan Hehn, Dipl.-Ing. (FH)
Operating Testing Officer
Material Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: B55-8F927