ift-Nachweis



Classification

Number	23-004224-PR01 (NW-K23-09-en-01)
Owner	Münchinger Holz GmbH Gewerbepark Wiedersbach 91578 Leutershausen Germany
Product	Symmetrically laminated profile of quality sorted and dried timber
Designation	Shipping name: Block profile 3-fold glued
Details	Material Laminated Oregon Pine; Configuration laminated cross section; Adhesive Technobond 4201/D4; Hardener Aluminium-Chlorid-Hardener; Cross section (W x T) 88 mm x 72 mm
Special features	-/-

Result **)

Classification of laminated profiles according to CEN/TS 13307-2:2009-12



The requirements for the service class 3 according to CEN/TS 13307-2 regarding the separation of layers are fulfilled.

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

Basis *)

EN 13307-1:2006-11

CEN/TS 13307-2:2009-12

*) and corresponding national versions (e.g. DIN EN)

Test report: 23-004224-PR01 PB-K23-09-de-01

Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.

When using this document the upto-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents' applies.

ift Rosenheim 08.08.2024

Michael Freinberger, Dipl.-Ing. (FH) Head of Testing Department Material Testing

******* +49 8031 261-0

info@ift-rosenheim.de www.ift-rosenheim.de

Stefan Hehn, Dipl.-Ing. (FH) Operating Testing Officer Material Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft ID: 5AC-D075E





