

Number	19-005118-PR01 (NW-K23-09-en-01)
Owner	Münchinger Holz GmbH Gewerbepark Wiedersbach 91578 Leutershausen Germany
Product	Symmetrically laminated and finger-jointed timber profile of quality sorted and dried timber
Designation	System: Lamella with and without finger joint
Details	Manufacturer Münchinger Holz GmbH; Material Spruce; Configuration longitudinally finger-jointed lamella; Type of adhesive 2K-Adhesive D4; Adhesive Jowacoll 102.25; Hardener Jowat Hardener 195.35; Cross section (W x T) 86 mm x 24 mm
Special features	-/-

Result

Classification of finger-jointed longitudinal joints according to
CEN/TS 13307-2 / DIN SPEC 1140:2009-12



The requirements for use class 3 according to CEN/TS 13307-2 with regard to the strength and tightness of the finger-joint longitudinal joint have been met.

Basis *)

EN 13307-1:2006-11
CEN/TS 13307-2:2009-12
*) and corresponding national versions
(e.g. DIN EN)
Test report: 19-005118-PR01 PB-K23-09-de-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
04.11.2020



Dr. Ing. Odette Moarcas
Project Engineer
Fire Safety



Stefan Hehn, Dipl.-Ing. (FH)
Operating Testing Officer
Material Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 445-D597C